



Lancaster General Health Hot Work Permit

This hot work permit is effective for one day for the date and time listed below. It is required for any work involving open flames or sparks, including but not limited to brazing, cutting, welding, soldering, thawing pipes, and grinding.

Hot work to be done by: Employee Contractor Company Name:				
Date submitted:	WO #:			
Start work Date:	Time:			
Permit expires Date:	Time:			
Location of Work :	If other, specify:			
Name or Person Performing Hot Work:				
Name or Person Performing Fire Watch:				
Signature of Hot Work Supervisor:				

CHECKLIST		No
Sprinklers in service in area of hot work		
Smoke detectors in area of hot work are		
protected to prevent false alarm		
Fire extinguishers are appropriate class and		
in the immediate area of hot work		
Flammable liquids removed from hot work		
area (35 feet radius)		
Combustible materials removed from hot		
work area (35 feet radius) or covered with		
fire resistant material (tarps, metal)		
Hot work equipment in good repair		
Wall & floor openings are covered		
Fire watch will be provided during work,		
including adjoining areas (above, below,		
and adjacent)		
Fire watch continues at least 30 minutes		
after work is completed. Hot work area is		
inspected.		
Person conducting fire watch is trained in		
use of fire extinguisher and emergency		
procedures		

Other precautions taken		NO
Confined space permit required		
Area is protected with smoke or heat		
detection		
Ample ventilation to remove smoke or		
vapor from work area		
Lockout/tag-out required		